From:	Eatch Beck - Capital Projects on behalf of Eatch Beck - Capital Projects <BeckE@ckschools.org>
To:	Lucas, Mike
Cc:	Killian, David
Subject:	RE: 20190122 - CKHSMS CDC 130 - Soule RD connection (003).pdf
Date:	Wednesday, January 30, 2019 12:31:01 PM

Excellent idea.
b

-----Original Message-----
From: Lucas, Mike <mike.lucas@skanska.com>
Sent: Wednesday, January 30, 2019 12:25 PM
To: Eatch Beck - Capital Projects <BeckE@ckschools.org>
Cc: Killian, David <David.Killian@skanska.com>
Subject: Re: 20190122 - CKHSMS CDC 130 - Soule RD connection (003).pdf

Beck,
I'm going to bring Mike out to job and have him show me how to do what he is referring too with neighbors property and more clashes . I'm not on site right now but I'm positive that he answered an past RFI last summer and Ceccanti had AHBL survey on site to help layout because if neighbors property and the issues. I'll look into it, but we are install per Hager. Thank you

Sent from Mike Lucas iPhone

> On Jan 30, 2019, at 11:08 AM, Eatch Beck - Capital Projects <BeckE@ckschools.org> wrote:
>
> [External Email]
> _____
> fyi
>
> From: Mike Hager <mhager@AHBL.com>
> Sent: Wednesday, January 30, 2019 10:59 AM
> To: Eatch Beck - Capital Projects <BeckE@ckschools.org>
> Cc: Nick Rheaume <NRheaume@AHBL.com>
> Subject: RE: 20190122 - CKHSMS CDC 130 - Soule RD connection (003).pdf
>
> They will need to regrade along the entire length of the tennis courts until it drops down the hill/swale. The exhibit has the note "CONSTRUCT MINIMUM 1' DEEP SWALE WITH 1:1 SIDE SLOPES AT 0.83%. MAINTAIN 1' DEPTH ALONG ENTIRE LENGTH". This note is pointing out the swale that was already a part of the plans, but was never constructed. This swale will need to be constructed in order for the area to drain.
>
> [cid:image001.png@01D4B88A.7156AB50]
>
> [cid:image002.png@01D4B88A.CFE647C0]
>
> Mike Hager | Project Engineer
> AHBL, Inc. | TACOMA • SEATTLE • SPOKANE • TRI-CITIES
> 253.383.2422 TEL | 253.284.0218 DIRECT | mhager@ahbl.com<mailto:mhager@ahbl.com> EMAIL | Send us a file<https://infoexchange.ahbl.com/UserWeb/Transfers/PersonalTransfer.aspx?personal=MHager@ahbl.com>.
>
> From: Eatch Beck - Capital Projects [mailto:BeckE@ckschools.org]
> Sent: Wednesday, January 30, 2019 10:27 AM
> To: Mike Hager
> Cc: Eatch Beck - Capital Projects; Nick Rheaume
> Subject: 20190122 - CKHSMS CDC 130 - Soule RD connection (003).pdf

> Importance: High
>
> Mike
> Attached is a comment back to you regarding the proposed solution.
>
> At the west end of the tennis courts the elevation goes up it appears that this solution might pond the water further down the tennis courts.
>
> beck
>
>
> <image001.png>
> <image002.png>

This message, including any attachments hereto, may contain privileged or confidential information and is sent solely for the attention and use of the intended addressee(s). If you are not an intended addressee, you may neither use this message nor copy or deliver it to anyone. In such case, you should immediately destroy this message and kindly notify the sender by reply email.
Thank you.