From:	Nick Rheaume on behalf of Nick Rheaume <NRheaume@AHBL.com>
To:	Eatch Beck - Capital Projects
Subject:	FW: CKHSMS - Soule Drainage & Tennis Swale Capacity
Date:	Tuesday, January 22, 2019 8:38:55 AM
Attachments:	20190117 - CKHSMS CDC 130 - Soule RD connection.pdf image003.png

---

Nick Rheaume, PE | Project Manager
AHBL, Inc. | **TACOMA** • SEATTLE • SPOKANE • TRI-CITIES
253.383.2422 **TEL** | 253.284.0285 **DIRECT** | nrheaume@ahbl.com **EMAIL** | Send us a file.

From: Mike Hager
Sent: Thursday, January 17, 2019 12:30 PM
To: Johnny Hong; Thiel Sydney - Capital Projects
Cc: Doreen Gavin; Nick Rheaume; Richard Wilson
Subject: RE: CKHSMS - Soule Drainage & Tennis Swale Capacity

Attached is the CDC-130 for the CCD-0105 regarding the tennis swale and neighbors roof drain.
Let me know if there is anything else needed.

Mike Hager | Project Engineer
AHBL, Inc. | **TACOMA** • SEATTLE • SPOKANE • TRI-CITIES
253.383.2422 **TEL** | 253.284.0218 **DIRECT** | mhager@ahbl.com **EMAIL** | Send us a file.

From: Johnny Hong [mailto:jhong@integrusarch.com]
Sent: Thursday, January 17, 2019 11:28 AM
To: Thiel Sydney - Capital Projects; Mike Hager
Cc: Doreen Gavin; Nick Rheaume; Richard Wilson
Subject: RE: CKHSMS - Soule Drainage & Tennis Swale Capacity

This will be CCD-0105.

Johnny Hong, AIA, LEED AP, Assoc. DBIA
Architect, Associate Principal
jhong@integrusarch.com

integrus ARCHITECTURE

Integrus Architecture
117 South Main Street, Suite 100
Seattle, WA 98104
206.628.3137 | office
206.794.6170 | cell

Need to send me a large file? Click here.

NOTICE: This email may contain confidential or privileged material, and is intended solely for use by the above referenced recipient. Any review, copying, printing, disclosure, distribution, or any other use, is strictly prohibited. If you are not the recipient, and believe that you have received this in error, please notify the sender and delete the copy you received.

From: Thiel Sydney - Capital Projects <SydneyT@ckschools.org>
Sent: Thursday, January 17, 2019 10:01 AM
To: 'Mike Hager' <mhager@AHBL.com>
Cc: licensing@ahbl.com <DGAVIN@AHBL.com>; Nick Rheaume <NRheaume@AHBL.com>; Johnny Hong <jhong@integrusarch.com>; Richard Wilson <rwilson@integrusarch.com>
Subject: RE: CKHSMS - Soule Drainage & Tennis Swale Capacity

Thank you, Mike.
Does AHBL need any further information to develop drawings to issue to the field?
I need to provide an update to the home owner about anticipate timeframe for the work to be done, but that can't be answered until Skanska receives the drawings.

Johnny/Richard,
Please identify the CCD number for this.

Thank you.

Sydney Thiel
Project Manager | Capital Projects Office
Central Kitsap School District | 9210 Silverdale Way NW, Silverdale, WA 98383
sydneyt@ckschools.org
360-662-1705 direct
206-960-2417 mobile

From: Mike Hager <mhager@AHBL.com>
Sent: Tuesday, January 15, 2019 9:32 AM
To: Thiel Sydney - Capital Projects <SydneyT@ckschools.org>
Cc: licensing@ahbl.com <DGAVIN@AHBL.com>; Nick Rheaume <NRheaume@AHBL.com>
Subject: CKHSMS - Soule Drainage & Tennis Swale Capacity

Hi Sydney,
I just returned your phone call but you must be busy at the moment. I approximated the drainage to the swale and its capacity. If the swale is built per plans it will support enough flow for the contributing area.

Mike Hager | Project Engineer
AHBL, Inc. | **TACOMA** • SEATTLE • SPOKANE • TRI-CITIES
253.383.2422 **TEL** | 253.284.0218 **DIRECT** | mhager@ahbl.com **EMAIL**

Civil Engineers • Structural Engineers • Landscape Architects • Community Planners • Land Surveyors
Visit us at www.ahbl.com. | Follow us on LinkedIn and Facebook. | Send us a file.