

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 03/28/2017

Expires 03/28/2019


Location Bldg. 805

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Water Heater	VA Number VA203847	NB Number 197395	Year Built 2014	Manufacturer AO SMITH
Allowable Pressure 160	Safety Valve Set 150	Inspection Company Hartford Steam Boiler		

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Hunt Manor Apartments
802 Hunt Ave NW,
Roanoke, VA 24012-4104



Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354110623

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 03/28/2017

Expires 03/28/2019


Location Bldg. 805 Blrm

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA046881	NB Number	Year Built 1970	Manufacturer American Standard
Allowable Pressure 50	Safety Valve Set 30	Inspection Company Hartford Steam Boiler		

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Hunt Manor Apartments
802 Hunt Ave NW,
Roanoke, VA 24012-4104



Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354110623