

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 2802 Slm Tnp

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109339	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2802 Salem Tpke NW,
Roanoke, VA 24017-5246

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 2802 Slm Tnp

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109340	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2802 Salem Tpke NW,
Roanoke, VA 24017-5246

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2636 Slm Tnp

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109341	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2642 Salem Tpke NW,
Roanoke, VA 24017-5334

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2636 Slm Tnp

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109342	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2642 Salem Tpke NW,
Roanoke, VA 24017-5334

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2636 Slm Tnp

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109343	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2642 Salem Tpke NW,
Roanoke, VA 24017-5334

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2551 Cntr Av

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109344	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2551 Centre Ave NW,
Roanoke, VA 24017-5353

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2501 Ctr Ave

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA117817	79209	1994	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2501 Centre Ave NW,
Roanoke, VA 24017-5347

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 621 30th St.

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA117826		1994	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
621 30th St NW,
Roanoke, VA 24017-5217

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2442 Delta

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA117828	13692	1994	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2442 Delta Dr NW,
Roanoke, VA 24017-5320

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2701 Gln Gry

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA117833	NB Number	Year Built 1994	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2701 Glengary Ave NW,
Roanoke, VA 24017-5231

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 2914 Slm Tpk

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA117860	NB Number 000	Year Built 1994	Manufacturer Burnham
Allowable Pressure	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2914 Salem Tpk NW,
Roanoke, VA 24017-5248

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2525 Ctr Ave

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA141556	NB Number	Year Built 1999	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2525 Centre Ave NW,
Roanoke, VA 24017-5347

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 616 Lucerne

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109309	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
616 Lucerne St NW,
Roanoke, VA 24017-5240

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

C. Ray Davenport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2735 Cntr Av

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109310	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2735 Centre Ave NW,
Roanoke, VA 24017-5258

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

C. Ray Davenport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2735 Cntr Av

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109311	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2735 Centre Ave NW,
Roanoke, VA 24017-5258

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

C. Ray Davenport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2735 Cntr Av

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109312	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2735 Centre Ave NW,
Roanoke, VA 24017-5258

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 609 Keats

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109313	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
609 Keats St NW,
Roanoke, VA 24017-5237

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 609 Keats

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109314	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
609 Keats St NW,
Roanoke, VA 24017-5237

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 609 Keats

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109315	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
609 Keats St NW,
Roanoke, VA 24017-5237

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 616 Keats

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109316	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
616 Keats St NW,
Roanoke, VA 24017-5238

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 616 Keats

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109317	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
616 Keats St NW,
Roanoke, VA 24017-5238

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 621 30th

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109320	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
621 30th St NW,
Roanoke, VA 24017-5217

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 621 30th

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109321	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
621 30th St NW,
Roanoke, VA 24017-5217

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 621 30th

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109322	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
621 30th St NW,
Roanoke, VA 24017-5217

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 633 30th

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109323	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
633 30th St NW,
Roanoke, VA 24017-5269

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 633 30th

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109324	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
633 30th St NW,
Roanoke, VA 24017-5269

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 2911 Glngry

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109325	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2721 Glengary Ave NW,
Roanoke, VA 24017-5231

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 2911 Glngry

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109326	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2721 Glengary Ave NW,
Roanoke, VA 24017-5231

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

C. Ray Overport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 2911 Glngry

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109327	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2721 Glengary Ave NW,
Roanoke, VA 24017-5231

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

C. Ray Overport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2721 Glngry

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109328	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2721 Glengary Ave NW,
Roanoke, VA 24017-5231

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

C. Ray Overport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2721 Glngry

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109329	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2721 Glengary Ave NW,
Roanoke, VA 24017-5231

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2721 Glngry

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109330	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2721 Glengary Ave NW,
Roanoke, VA 24017-5231

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2701 Glngry

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109331	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2701 Glengary Ave NW,
Roanoke, VA 24017-5231

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 2914 Slm Tnp

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109332	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2914 Salem Tpke NW,
Roanoke, VA 24017-5248

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 2914 Slm Tnp

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109333	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2914 Salem Tpke NW,
Roanoke, VA 24017-5248

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 2812 Slm Tnp

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109335	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2812 Salem Tpke NW,
Roanoke, VA 24017-5246

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 2812 Slm Tnp

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109336	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2812 Salem Tpke NW,
Roanoke, VA 24017-5246

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 2812 Slm Tnp

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109337	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2812 Salem Tpke NW,
Roanoke, VA 24017-5246

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 2802 Slm Tnp

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109338	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2802 Salem Tpke NW,
Roanoke, VA 24017-5246

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2457 Delta

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA001179	NB Number	Year Built 1991	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2457 Delta Dr NW,
Roanoke, VA 24017-5319

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2457 Delta

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA001180	NB Number	Year Built 1991	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2457 Delta Dr NW,
Roanoke, VA 24017-5319

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2624 Slm Tnp

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Fire Tube Boiler	VA Number VA003897	NB Number 31324	Year Built 1978	Manufacturer Kewanee
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2624 Salem Tpk NW,
Roanoke, VA 24017-5334

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2447 Cntr Ave

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA007101	NB Number	Year Built 1991	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2447 Centre Ave NW,
Roanoke, VA 24017-5345

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2447 Cntr Av

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA007102	NB Number	Year Built 1991	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2447 Centre Ave NW,
Roanoke, VA 24017-5345

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2624 Slm Tnp

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Fire Tube Boiler	VA Number VA007108	NB Number 42869	Year Built 1990	Manufacturer Kewanee
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2624 Salem Tpk NW,
Roanoke, VA 24017-5334

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2701 Glngry

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA007111	NB Number	Year Built 1991	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2701 Glengary Ave NW,
Roanoke, VA 24017-5231

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 2747 Glngry

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA007112	NB Number	Year Built 1991	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2747 Glengary Ave NW,
Roanoke, VA 24017-5231

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 2747 Glngry

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA007113	NB Number	Year Built 1991	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2747 Glengary Ave NW,
Roanoke, VA 24017-5231

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 2747 Glngry

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA007114	NB Number	Year Built 1991	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2747 Glengary Ave NW,
Roanoke, VA 24017-5231

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 616 Keats

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA007118	NB Number	Year Built 1991	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
616 Keats St NW,
Roanoke, VA 24017-5238

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 2905 Cntr Av

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA007119	NB Number	Year Built 1991	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2905 Centre Ave NW,
Roanoke, VA 24017-5260

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2624 Slm Tnp

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Air Tank	VA Number VA007123	NB Number 427924	Year Built 1986	Manufacturer Manchester
Allowable Pressure 200	Safety Valve Set 200	Inspection Company Hartford Steam Boiler		

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2624 Salem Tpke NW,
Roanoke, VA 24017-5334

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2525 Cntr Av

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA092275	NB Number	Year Built 1989	Manufacturer Burnham
Allowable Pressure	Safety Valve Set 30	Inspection Company Hartford Steam Boiler		

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2525 Centre Ave NW,
Roanoke, VA 24017-5347

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2452 Slm Tnp

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA107751	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30	Inspection Company Hartford Steam Boiler		

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2452 Salem Tpke NW,
Roanoke, VA 24017-5354

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2452 Slm Tnp

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107752		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2452 Salem Tpke NW
Roanoke, VA 24017-5354

C. Ray Overport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2452 Slm Tnp

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107753		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2452 Salem Tpke NW
Roanoke, VA 24017-5354

C. Ray Overport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2520 Slm Tnp

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107754		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2520 Salem Tpke NW
Roanoke, VA 24017-5332

C. Ray Overport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2520 Slm Tnp

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA107755	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2520 Salem Tpke NW,
Roanoke, VA 24017-5332

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

C. Ray Davenport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2520 Slm Tnp

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA107756	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2520 Salem Tpke NW,
Roanoke, VA 24017-5332

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

C. Ray Davenport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2515 Delta

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA107757	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2515 Delta Dr NW,
Roanoke, VA 24017-5321

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

C. Ray Davenport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2515 Delta

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107758		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2515 Delta Dr NW
Roanoke, VA 24017-5321

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2515 Delta

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107759		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2515 Delta Dr NW
Roanoke, VA 24017-5321

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2415 Delta

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107760		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2415 Delta Dr NW
Roanoke, VA 24017-5319

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2415 Delta

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA107761	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2415 Delta Dr NW,
Roanoke, VA 24017-5319

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2415 Delta

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA107762	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2415 Delta Dr NW,
Roanoke, VA 24017-5319

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2418 Delta

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA107763	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2418 Delta Dr NW,
Roanoke, VA 24017-5320

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2418 Delta

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA107764	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2418 Delta Dr NW,
Roanoke, VA 24017-5320

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

C. Ray Davenport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2418 Delta

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA107765	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2418 Delta Dr NW,
Roanoke, VA 24017-5320

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

C. Ray Davenport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2442 Delta

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA107767	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2442 Delta Dr NW,
Roanoke, VA 24017-5320

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

C. Ray Davenport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2502 Delta

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA107769	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2502 Delta Dr NW,
Roanoke, VA 24017-5322

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2502 Delta

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA107770	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2502 Delta Dr NW,
Roanoke, VA 24017-5322

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2502 Delta

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA107771	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2502 Delta Dr NW,
Roanoke, VA 24017-5322

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2520 Delta

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107772		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2526 Delta Dr NW
Roanoke, VA 24017-5322

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2520 Delta

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107773		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2526 Delta Dr NW
Roanoke, VA 24017-5322

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2415 Cntr Av

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107775		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2415 Centre Ave NW,
Roanoke, VA 24017-5345

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2415 Cntr Av

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA107776	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2415 Centre Ave NW,
Roanoke, VA 24017-5345

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2415 Cntr Av

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA107777	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2415 Centre Ave NW,
Roanoke, VA 24017-5345

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2551 Cntr Av

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA107778	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2551 Centre Ave NW,
Roanoke, VA 24017-5353

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2551 Cntr Av

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107779		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2551 Centre Ave NW,
Roanoke, VA 24017-5353

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2501 Cntr Av

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107781		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2501 Centre Ave NW,
Roanoke, VA 24017-5347

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2525 Cntr Av

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107783		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2525 Centre Ave NW,
Roanoke, VA 24017-5347

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2535 Cntr Av

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107786		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2535 Centre Ave NW,
Roanoke, VA 24017-5353

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2535 Cntr Av

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107787		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2535 Centre Ave NW,
Roanoke, VA 24017-5353

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2535 Cntr Av

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107788		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2535 Centre Ave NW,
Roanoke, VA 24017-5353

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 609 Milton

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107789		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
609 Milton St NW,
Roanoke, VA 24017-5241

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 609 Milton

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107790		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
609 Milton St NW,
Roanoke, VA 24017-5241

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 609 Milton

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107791		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
609 Milton St NW,
Roanoke, VA 24017-5241

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 616 Milton

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107792		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
616 Milton St NW,
Roanoke, VA 24017-5242

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 616 Milton

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107793		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
616 Milton St NW,
Roanoke, VA 24017-5242

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 616 Milton

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107794		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
616 Milton St NW,
Roanoke, VA 24017-5242

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 2905 Cntr Av

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA107800	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2905 Centre Ave NW,
Roanoke, VA 24017-5260

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2717 Cntr Av

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109301	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2717 Centre Ave NW,
Roanoke, VA 24017-5257

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2717 Cntr Av

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109302	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2717 Centre Ave NW,
Roanoke, VA 24017-5257

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2717 Cntr Av

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109303	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2717 Centre Ave NW,
Roanoke, VA 24017-5257

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 609 Lucerne

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109304	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
609 Lucerne St NW,
Roanoke, VA 24017-5239

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 609 Lucerne

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109305	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
609 Lucerne St NW,
Roanoke, VA 24017-5239

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 609 Lucerne

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109306	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
609 Lucerne St NW,
Roanoke, VA 24017-5239

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

C. Ray Davenport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 616 Lucerne

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109307	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
616 Lucerne St NW,
Roanoke, VA 24017-5240

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

C. Ray Davenport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/21/2017

Location 616 Lucerne

Expires 06/21/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA109308	NB Number	Year Built 1993	Manufacturer Burnham
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
616 Lucerne St NW,
Roanoke, VA 24017-5240

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354112853

C. Ray Davenport

Commissioner

ost this certificate in a conspicuous and protect place near the equipment. May be invoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

Roanoke Redevel. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2624 Salem Tpk NW
Roanoke, VA 24017-5334

C. Ray Chaves

Commissioner

tion 2447 Cntr Av
his certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.
/pe Equipment
ast Iron Boiler
owable Pressure

VA Number VA205039
NB Number 12036898
Safety Valve Set 30

Year Built 1993
Inspection Company
Manufacturer Burnham
Hartford Steam Boiler

Expires 06/20/2019

Date of Insp 06/20/2017

**COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION**

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/20/2017

Location 2457 Delta

Expires 06/20/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA001178		1991	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
2457 Delta Dr NW,
Roanoke, VA 24017-5319

Post this certificate in a conspicuous and protected place near the equipment. May be
revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354112853

C. Ray Davenport

Commissioner

**COMMONWEALTH OF VIRGINIA
Department of Labor and Industry
Boiler Safety Compliance Program**

Main Street Centre
600 East Main Street, Suite 207, Richmond Virginia 23219
Telephone Number (804) 786-3160

INVOICE NO. 954116491

DATE 11/28/2017

As provided for by Chapter 3.1 of the Labor Laws of Virginia, the equipment listed below has been inspected by:
Authorized Inspection Agency: Hartford Steam Boiler

USER
Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

OWNER

Make check or money order payable to the **DOLI / BOILER SAFETY.**
Return the original invoice with the total amount shown.
When payment is received, the required Certificate of Inspection will be forwarded.

Total Certificate of Inspection Fees [\$20.00 each]: No. 3 \$ 60.00
Total Inspection Fees \$ 0.00

Pay Total Amount \$ **\$60.00**

Payment Due By: 12/28/2017

Location	Type of Equipment	VA Number	Date Inspected	Inspection (Int/Ext)	Inspection Fee
Lansdowne Park, 617 Naho St., 617 Naho St NW, , Roanoke	Cast Iron Boiler	VA007120	11/06/2017	External	0.00
Lansdowne Park, 617 Naho St., 617 Naho St NW, , Roanoke	Cast Iron Boiler	VA007122	11/06/2017	External	0.00
Lansdowne Park, 617 Naho St., 617 Naho St NW, , Roanoke	Cast Iron Boiler	VA107785	11/06/2017	External	0.00

NOTICE:

§40.1-51.12 Unlawful to operate boiler or pressure vessel without inspection certificate; Penalty...The operation of a boiler or pressure vessel without such inspection certificate...shall constitute a misdemeanor on the part of the owner, user or operator or agent... and shall be punishable by a fine not exceeding one hundred dollars. Each day of such unlawful operation shall be deemed a separate offense. (1972, c.237.)

This is in accordance with the Virginia Boiler and Pressure Vessel Safety Act.

**COMMONWEALTH OF VIRGINIA
Department of Labor and Industry
Boiler Safety Compliance Program**

Main Street Centre
600 East Main Street, Suite 207, Richmond Virginia 23219
Telephone Number (804) 786-3160

INVOICE NO. 954116491

DATE 11/28/2017

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Make Check or money order payable to the **DOLI / BOILER SAFETY**.
Return the Remittance Copy with the total amount shown.
When payment is received, the required Certificate of Inspection will be forwarded.
Cost of each certificate is \$20.00

Inspected By: Hartford Steam Boiler

Remittance Copy

Please Return This Page With Payment

Amount Due: \$60.00

PLEASE NOTE WE HAVE MOVED. OUR NEW ADDRESS IS:

**COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
600 EAST MAIN STREET, SUITE 207
RICHMOND, VA 23219**

Tel: (804) 786-3160 Web: doli.virginia.gov

NOTICE:

§40.1-51.12 Unlawful to operate boiler or pressure vessel without inspection certificate: Penalty...The operation of a boiler or pressure vessel without such inspection certificate...shall constitute a misdemeanor on the part of the owner, user or operator or agent... and shall be punishable by a fine not exceeding one hundred dollars. Each day of such unlawful operation shall be deemed a separate offense. (1972, c.237.)

This is in accordance with the Virginia Boiler and Pressure Vessel Safety Act.

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 11/06

Location 2905 Center Ave

Expires 11/06

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA213008		2006	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
50	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Joel Shank
2624 Salem Tpke NW
Roanoke, VA 24017-5334

Object Located At:
Roanoke Redev. & Housing
2624 Salem Tpke NW
Roanoke, VA 24017-5334

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
954116652

C. Ray Davenport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 11/06/2017

Location 617 Naho St.

Expires 11/06/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA007120	12792	1991	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
617 Naho St NW
Roanoke, VA 24017-5349

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

954116491

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 11/06/2017

Location 617 Naho St.

Expires 11/06/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA007122		1991	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
617 Naho St NW
Roanoke, VA 24017-5349

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

954116491

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 11/06/2017

Location 617 Naho St.

Expires 11/06/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Cast Iron Boiler	VA107785		1993	Burnham
Allowable Pressure	Safety Valve Set		Inspection Company	
30	30		Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Lansdowne Park
617 Naho St NW
Roanoke, VA 24017-5349

C. Ray Davenport

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

954116491

RECEIVED

JAN 09 2018

LANSLOWNE PARK