

COMMONWEALTH OF VIRGINIA  
DEPARTMENT OF LABOR AND INDUSTRY  
BOILER SAFETY COMPLIANCE PROGRAM  
CERTIFICATE OF INSPECTION

Date of Insp 03/08/2017

Location Boiler Rm

Expires 03/08/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

<b>Type Equipment</b> Cast Iron Boiler	<b>VA Number</b> VA123829	<b>NB Number</b>	<b>Year Built</b> 1995	<b>Manufacturer</b> Burnham
<b>Allowable Pressure</b> 50	<b>Safety Valve Set</b> 30		<b>Inspection Company</b> Hartford Steam Boiler	

Roanoke Redev. & Housing  
Attn: Catina Lowery  
2624 Salem Turnpike NW  
Roanoke, VA 24017

**Object Located At:**  
Lincoln Terrace  
1801 Dunbar St NW,  
Roanoke, VA 24012-4628



Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.  
354110212

COMMONWEALTH OF VIRGINIA  
DEPARTMENT OF LABOR AND INDUSTRY  
BOILER SAFETY COMPLIANCE PROGRAM  
CERTIFICATE OF INSPECTION

Date of Insp 03/08/2017

Location Boiler Room

Expires 03/08/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

<b>Type Equipment</b> Cast Iron Boiler	<b>VA Number</b> VA123830	<b>NB Number</b>	<b>Year Built</b> 1975	<b>Manufacturer</b> American Standard
<b>Allowable Pressure</b> 50	<b>Safety Valve Set</b> 50		<b>Inspection Company</b> Hartford Steam Boiler	

Roanoke Redev. & Housing  
Attn: Catina Lowery  
2624 Salem Turnpike NW  
Roanoke, VA 24017

**Object Located At:**  
Lincoln Terrace  
1801 Dunbar St NW,  
Roanoke, VA 24012-4628



Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.  
354110212