

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 02/06/2017

Location Boiler Room

Expires 02/06/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Air Tank	VA Number VA169619	NB Number 375472	Year Built 2004	Manufacturer Manchester
Allowable Pressure 200	Safety Valve Set 200	Inspection Company Hartford Steam Boiler		

Roanoke RHA
Attn: Joel Shank
2624 Salem Tpke NW
Roanoke, VA 24017-5334

Object Located At:
Melrose Towers
3038 Melrose Ave NW,
Roanoke, VA 24017-5933

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354109503

C. Ray Davenport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 02/06/2017

Location Boiler Room

Expires 02/06/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA192654	NB Number 212455	Year Built 2012	Manufacturer Raypak
Allowable Pressure 160	Safety Valve Set 60	Inspection Company Hartford Steam Boiler		

Roanoke RHA
Attn: Joel Shank
2624 Salem Tpke NW
Roanoke, VA 24017-5334

Object Located At:
Melrose Towers
3038 Melrose Ave NW,
Roanoke, VA 24017-5933

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354109503

C. Ray Davenport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 02/06/2017

Location Boiler Room

Expires 02/06/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA192655	NB Number 212434	Year Built 2012	Manufacturer Raypak
Allowable Pressure 160	Safety Valve Set 60	Inspection Company Hartford Steam Boiler		

Roanoke RHA
Attn: Joel Shank
2624 Salem Tpke NW
Roanoke, VA 24017-5334

Object Located At:
Melrose Towers
3038 Melrose Ave NW,
Roanoke, VA 24017-5933

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354109503

C. Ray Davenport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 02/06/2017

Location Boiler Room

Expires 02/06/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA192656	NB Number 212437	Year Built 2012	Manufacturer Raypak
Allowable Pressure 160	Safety Valve Set 60	Inspection Company Hartford Steam Boiler		

Roanoke RHA
Attn: Joel Shank
2624 Salem Tpke NW
Roanoke, VA 24017-5334

Object Located At:
Melrose Towers
3038 Melrose Ave NW
Roanoke, VA 24017-5933

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354109503

C. Ray Davenport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 02/06/2017

Location Boiler Room

Expires 02/06/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Cast Iron Boiler	VA Number VA192657	NB Number 210882	Year Built 2012	Manufacturer Raypak
Allowable Pressure 160	Safety Valve Set 60	Inspection Company Hartford Steam Boiler		

Roanoke RHA
Attn: Joel Shank
2624 Salem Tpke NW
Roanoke, VA 24017-5334

Object Located At:
Melrose Towers
3038 Melrose Ave NW
Roanoke, VA 24017-5933

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354109503

C. Ray Davenport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 02/06/2017

Location Boiler Room

Expires 02/06/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Water Tube Boiler	VA Number VA192658	NB Number 205001	Year Built 2012	Manufacturer A.O. Smith
Allowable Pressure 160	Safety Valve Set 125	Inspection Company Hartford Steam Boiler		

Roanoke RHA
Attn: Joel Shank
2624 Salem Tpke NW
Roanoke, VA 24017-5334

Object Located At:
Melrose Towers
3038 Melrose Ave NW
Roanoke, VA 24017-5933

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.
354109503

C. Ray Davenport

Commissioner

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 02/06/2017

Location Boiler Room

Expires 02/06/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment	VA Number	NB Number	Year Built	Manufacturer
Water Tube Boiler	VA192659	205000	2012	A.O. Smith
Allowable Pressure	Safety Valve Set		Inspection Company	
160	125		Hartford Steam Boiler	

Roanoke RHA
Attn: Joel Shank
2624 Salem Tpke NW
Roanoke, VA 24017-5334

Object Located At:
Melrose Towers
3038 Melrose Ave NW
Roanoke, VA 24017-5933

C. Ray Edwards

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354109503

Commissioner