

COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION

Date of Insp 06/27/2016

Location boiler room

Expires 06/27/2018

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

Type Equipment Water Tube Boiler	VA Number VA190298	NB Number 60885	Year Built 2012	Manufacturer Aerco
Allowable Pressure 160	Safety Valve Set 75	Inspection Company Hartford Steam Boiler		

Roanoke Redev. & Housing
Attn: Denise Stanley - Prop.Mgr
2624 Salem Tpke NW
Roanoke, VA 24017-5334

Object Located At:
Morningside Manor
1020 13th St SE,
Roanoke, VA 24013-2047

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

954103284



Commissioner