

COMMONWEALTH OF VIRGINIA  
DEPARTMENT OF LABOR AND INDUSTRY  
BOILER SAFETY COMPLIANCE PROGRAM  
CERTIFICATE OF INSPECTION

Date of Insp 06/27/2016

Location boiler room

Expires 06/27/2018

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

<b>Type Equipment</b> Water Tube Boiler	<b>VA Number</b> VA190299	<b>NB Number</b> 60193	<b>Year Built</b> 2012	<b>Manufacturer</b> Aerco
<b>Allowable Pressure</b> 160	<b>Safety Valve Set</b> 75	<b>Inspection Company</b> Hartford Steam Boiler		

Roanoke Redev. & Housing  
Attn: Denise Stanley - Prop.Mgr  
2624 Salem Tpke NW  
Roanoke, VA 24017-5334

**Object Located At:**  
Morningside Manor  
1020 13th St SE,  
Roanoke, VA 24013-2047

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

954103284



---

Commissioner