

**COMMONWEALTH OF VIRGINIA
DEPARTMENT OF LABOR AND INDUSTRY
BOILER SAFETY COMPLIANCE PROGRAM
CERTIFICATE OF INSPECTION**

Date of Insp 03/28/2017

Location Bldg. 802

Expires 03/28/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.


Type Equipment Cast Iron Boiler	VA Number VA129207	NB Number	Year Built 1970	Manufacturer American Standard
Allowable Pressure 30	Safety Valve Set 30		Inspection Company Hartford Steam Boiler	

Roanoke Redev. & Housing
Attn: Catina Lowery
2624 Salem Turnpike NW
Roanoke, VA 24017

Object Located At:
Hunt Manor Apartments
802 Hunt Ave NW,
Roanoke, VA 24012-4104

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354110623



Commissioner