

COMMONWEALTH OF VIRGINIA  
DEPARTMENT OF LABOR AND INDUSTRY  
BOILER SAFETY COMPLIANCE PROGRAM  
CERTIFICATE OF INSPECTION

Date of Insp 03/28/2017

Expires 03/28/2019

Location Bldg. 810

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

<b>Type Equipment</b> Water Heater	<b>VA Number</b> VA203846	<b>NB Number</b> 161836	<b>Year Built</b> 2011	<b>Manufacturer</b> AO SMITH
<b>Allowable Pressure</b> 160	<b>Safety Valve Set</b> 150	<b>Inspection Company</b> Hartford Steam Boiler		

Roanoke Redev. & Housing  
Attn: Catina Lowery  
2624 Salem Turnpike NW  
Roanoke, VA 24017

**Object Located At:**  
Hunt Manor Apartments  
802 Hunt Ave NW,  
Roanoke, VA 24012-4104

*C. Ray Cavensport*

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354110623

COMMONWEALTH OF VIRGINIA  
DEPARTMENT OF LABOR AND INDUSTRY  
BOILER SAFETY COMPLIANCE PROGRAM  
CERTIFICATE OF INSPECTION

Date of Insp 03/28/2017

Expires 03/28/2019

Location 811/Boiler Room

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

<b>Type Equipment</b> Cast Iron Boiler	<b>VA Number</b> VA129214	<b>NB Number</b>	<b>Year Built</b> 1970	<b>Manufacturer</b> American Standard
<b>Allowable Pressure</b> 30	<b>Safety Valve Set</b> 30	<b>Inspection Company</b> Hartford Steam Boiler		

Roanoke Redev. & Housing  
Attn: Catina Lowery  
2624 Salem Turnpike NW  
Roanoke, VA 24017

**Object Located At:**  
Hunt Manor Apartments  
802 Hunt Ave NW,  
Roanoke, VA 24012-4104

*C. Ray Cavensport*

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354110623

COMMONWEALTH OF VIRGINIA  
DEPARTMENT OF LABOR AND INDUSTRY  
BOILER SAFETY COMPLIANCE PROGRAM  
CERTIFICATE OF INSPECTION

Date of Insp 03/28/2017

Expires 03/28/2019

Location 812/Boiler Room

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

<b>Type Equipment</b> Cast Iron Boiler	<b>VA Number</b> VA046887	<b>NB Number</b>	<b>Year Built</b> 1970	<b>Manufacturer</b> American Standard
<b>Allowable Pressure</b> 50	<b>Safety Valve Set</b> 30	<b>Inspection Company</b> Hartford Steam Boiler		

Roanoke Redev. & Housing  
Attn: Catina Lowery  
2624 Salem Turnpike NW  
Roanoke, VA 24017

**Object Located At:**  
Hunt Manor Apartments  
802 Hunt Ave NW,  
Roanoke, VA 24012-4104

*C. Ray Cavensport*

Commissioner

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354110623