

**COMMONWEALTH OF VIRGINIA  
DEPARTMENT OF LABOR AND INDUSTRY  
BOILER SAFETY COMPLIANCE PROGRAM  
CERTIFICATE OF INSPECTION**

Date of Insp 03/28/2017

Location Bldg. 803

Expires 03/28/2019

This certifies that the equipment described herein has been inspected and may be operated at the designated location at a pressure not to exceed that shown.

<b>Type Equipment</b> Water Heater	<b>VA Number</b> VA203848	<b>NB Number</b> 161839	<b>Year Built</b> 2011	<b>Manufacturer</b> AO SMITH
<b>Allowable Pressure</b> 160	<b>Safety Valve Set</b> 150	<b>Inspection Company</b> Hartford Steam Boiler		

Roanoke Redev. & Housing  
Attn: Catina Lowery  
2624 Salem Turnpike NW  
Roanoke, VA 24017

**Object Located At:**  
Hunt Manor Apartments  
802 Hunt Ave NW  
Roanoke, VA 24012-4104

Post this certificate in a conspicuous and protected place near the equipment. May be revoked for failure to keep equipment in safe condition or nonpayment of certificate fee.

354110623

*C. Ray Davenport*

---

Commissioner